



# Performance Data Sheet

Multipure Drinking Water Systems have been tested and certified under NSF/ANSI Standard Nos. 53 as shown below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in NSF/ANSI 53, Health Effects.



For Model Nos. MP750SB, MP1200EL, MP750SC, MP750SI, MPAD

Substance	Percent Reduction**	Influent challenge concentration (mg/L unless specified)	Maximum permissible product water concentration (mg/L unless specified)
ALACHLOR*	>98%	0.05	0.001
ASBESTOS	>99.9%	10 <sup>7</sup> to 10 <sup>8</sup> fibers/L; fibers greater than 10 micrometers in length	99% reduction requirement
ATRAZINE*	>97%	0.1	0.003
BENZENE*	>99%	0.081	0.001
BROMODICHLOROMETHANE (TTHM)*	>99.8%	0.300 +/- 0.30	0.015
BROMOFORM (TTHM)*	>99.8%	0.300 +/- 0.30	0.015
CARBOFURAN (Furadan)*	>99%	0.19	0.001
CARBON TETRACHLORIDE*	98%	0.078	0.0018
CHLORDANE	>99.5%	0.04 +/- 10%	0.002
CHLOROBENZENE (Monochlorobenzene)*	>99%	0.077	0.001
CHLOROPICRIN*	99%	0.015	0.0002
CHLOROFORM (TTHM)* (surrogate chemical)	>99.8%	0.300 +/- 0.30	0.015
Cryptosporidium (CYST)	99.95%	minimum 50,000/mL	99.95%
CYST (Giardia; Cryptosporidium; Entamoeba; Toxoplasma)	99.95%	minimum 50,000/mL	99.95%
2, 4-D*	98%	0.110	0.0017
DBCP (see Dibromochloropropane)*	>99%	0.052	0.00002
1,2-DCA (see 1,2-DICHLOROETHANE)*	95%	0.088	0.0048
1,1-DCE (see 1,1-DICHLOROETHYLENE)*	>99%	0.083	0.001
DIBROMOCHLOROMETHANE (TTHM; Chlorodibromomethane)*	>99.8%	0.300 +/- 0.30	0.015
DIBROMOCHLOROPROPANE (DBCP)*	>99%	0.052	0.00002
o-DICHLOROBENZENE (1,2 Dichlorobenzene)*	>99%	0.08	0.001
p-DICHLOROBENZENE (para-Dichlorobenzene)*	>98%	0.04	0.001
1,2-DICHLOROETHANE (1,2-DCA)*	95%	0.088	0.0048
1,1-DICHLOROETHYLENE (1,1-DCE)*	>99%	0.083	0.001
CIS-1,2-DICHLOROETHYLENE*	>99%	0.17	0.0005
TRANS-1,2- DICHLOROETHYLENE*	>99%	0.086	0.001
1,2-DICHLOROPROPANE (Propylene Dichloride)*	>99%	0.08	0.001
CIS-1,3- DICHLOROPROPYLENE*	>99%	0.079	0.001
DINOSEB*	99%	0.17	0.0002
EDB (see ETHYLENE DIBROMIDE)*	>99%	0.044	0.00002
ENDRIN*	98%	0.053	0.00059
Entamoeba (see CYSTS)	99.95%	minimum 50,000/mL	99.95%
ETHYLBENZENE*	>99%	0.088	0.001
ETHYLENE DIBROMIDE (EDB)*	>99%	0.044	0.00002

\*\*Percent reduction reflects actual performance of Multipure product as specifically tested (at 200% of capacity). Percent reduction shown for VOCs\* reflects the allowable claims for Volatile Organic Chemicals/Compounds as per Tables. Chloroform was used as a surrogate for VOC reduction claims: the Multipure Systems' actual reduction rate of Chloroform was >99.8% as tested (at 200% of capacity).

<b>Substance</b>	<b>Percent Reduction**</b>	<b>Influent challenge concentration (mg/L unless specified)</b>	<b>Maximum permissible product water concentration (mg/L unless specified)</b>
Giardia Lamblia (see CYST)	>99.95%	minimum 50,000/mL	99.95%
<b>HALOACETONITRILES (HAN)*</b>			
<b>BROMOCHLOROACETONITRILE</b>	98%	0.022	0.0005
<b>DIBROMOACETONITRILE</b>	98%	0.024	0.0006
<b>DICHLOROACETONITRILE</b>	98%	0.0096	0.0002
<b>TRICHLOROACETONITRILE</b>	98%	0.015	0.0003
<b>HALOKETONES (HK):*</b>			
<b>1,1-DICHLORO-2-PROPANONE</b>	99%	0.0072	0.0001
<b>1,1,1-TRICHLORO-2-PROPANONE</b>	96%	0.0082	0.0003
<b>HEPTACHLOR*</b>	>99%	0.25	0.00001
<b>HEPTACHLOR EPOXIDE*</b>	98%	0.0107	0.0002
<b>HEXACHLOROBUTADIENE (Perchlorobutadiene)*</b>	>98%	0.044	0.001
<b>HEXACHLOROCYCLOPENTADIENE*</b>	>99%	0.060	0.000002
<b>LEAD (pH 6.5)</b>	>99.3%	0.15 +/- 10%	0.010
<b>LEAD (pH 8.5)</b>	>99.3%	0.15 +/- 10%	0.010
<b>LINDANE*</b>	>99%	0.055	0.00001
<b>MERCURY (pH 6.5)</b>	>99%	0.006 +/- 10%	0.002
<b>MERCURY (pH 8.5)</b>	>99%	0.006 +/- 10%	0.002
<b>METHOXYCHLOR*</b>	>99%	0.050	0.0001
Methylbenzene (see TOLUENE)*	>99%	0.078	0.001
Monochlorobenzene (see CHLOROENZENE)*	>99%	0.077	0.001
<b>MTBE (methyl tert-butyl ether)</b>	>96.6%	0.015 +/- 20%	0.005
<b>POLYCHLORINATED BIPHENYLS (PCBs , Aroclor 1260)</b>	>99.9%	0.01 +/- 10%	0.0005
PCE (see TETRACHLOROETHYLENE)*	>99%	0.081	0.001
<b>PENTACHLOROPHENOL*</b>	>99%	0.096	0.001
Perchlorobutadiene (see HEXACHLOROBUTADIENE)*	>98%	0.044	0.001
Propylene Dichloride (see 1,2 -DICHLOROPROPANE)*	>99%	0.080	0.001
<b>RADON</b>	>94.9%	4000 ± 1000 pCi/L	300 pCi/L
<b>SIMAZINE*</b>	>97%	0.120	0.004
Silvex (see 2,4,5-TP)*	99%	0.270	0.0016
<b>STYRENE (Vinylbenzene)*</b>	>99%	0.15	0.0005
1,1,1-TCA (see 1,1,1 - TRICHLOROETHANE)*	95%	0.084	0.0046
TCE (see TRICHLOROETHYLENE)*	>99%	0.180	0.0010
<b>1,1,2- TETRACHLOROETHANE*</b>	>99%	0.081	0.001
<b>TETRACHLOROETHYLENE*</b>	>99%	0.081	0.001
<b>TOLUENE (Methylbenzene)*</b>	>99%	0.078	0.001
<b>TOXAPHENE</b>	>92.9%	0.015 +/- 10%	0.003
Toxoplasma (see CYSTS)	99.95%	minimum 50,000/mL	99.95%
<b>2,4,5-TP (Silvex)*</b>	99%	0.270	0.0016
<b>TRIBROMOACETIC ACID*</b>	98%	0.042	0.001
<b>1,2,4 TRICHLOROENZENE (Unsymtrichlorobenzene)*</b>	>99%	0.160	0.0005
<b>1,1,1-TRICHLOROETHANE (1,1,1-TCA)*</b>	95%	0.084	0.0046
<b>1,1,2-TRICHLOROETHANE*</b>	>99%	0.150	0.0005
<b>TRICHLOROETHYLENE (TCE)*</b>	>99%	0.180	0.0010
<b>TRIALOMETHANES (TTHM) (Chloroform; Bromoform; Bromodichloromethane; Dibromochloromethane)</b>	>99.8%	0.300 +/- 0.30	0.015
<b>TURBIDITY</b>	>99%	11 +/- 1 NTU	0.5 NTU
Unsym-Trichlorobenzene (see 1,2,4-TRICHLOROENZENE)*	>99%	0.160	0.0005
Vinylbenzene (see STYRENE)*	>99%	0.150	0.0005
<b>XYLENES (TOTAL)*</b>	>99%	0.070	0.001

## NSF/ANSI 42 - Aesthetic Effects

The System has been tested according to NSF/ANSI Standard 42 for the reduction of the following substances. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system.

Substance	Percent Reduction <sup>**</sup>	Influent challenge concentration (mg/L unless specified)	Maximum permissible product water concentration (mg/L unless specified)
<b>CHLORAMINE as Aesthetic Effect</b> (As Monochloramine)	>97%	3.0 mg/L +/- 10%	0.5 mg/L
<b>CHLORINE as Aesthetic Effect</b>	99%	2.0 Mg/L +/- 10%	> or = 50%
<b>PARTICULATE</b> , (Nominal Particulate Reduction, Class I, Particles 0.5 TO <1 UM	Class I > 99%	At Least 10,000 particles/mL	> or = 85%

Note: This addresses the U.S. Environmental Protection Agency (EPA) Primary and Secondary Drinking Water Regulations in effect at its time of publication, they relate to Multipure's performance in conformance to the industry performance criteria. These regulations are continually being updated at the Federal level. Accordingly, this list of MCLs will be reviewed and amended when appropriate. Please see sales brochure for list of product certifications.

### NOTES:

1. Multipure Drinking Water Systems have been certified, as indicated, by NSF International for compliance to NSF/ANSI Standard Nos. 42 & 53.
2. The Multipure Drinking Water Systems have been certified by the State of California Department of Public Health for the reduction of specific contaminants listed herein.
3. Chloroform was used as a surrogate for claims of reduction of VOCs. Multipure Systems tested at >99.8% actual reduction of Chloroform. Percent reduction shown herein reflects the allowable claims for VOCs as per tables in the Standard.
4. **Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected water that may contain filterable cysts.**
5. Filter life will vary in proportion to the amount of water used and the level of impurities in the water being processed. For optimum performance, it is essential that the filter be replaced on a regularly scheduled basis as follows: (a) annually; (b) when the unit's rated capacity has been reached; (c) the flow rate diminishes; or (d) the filter becomes saturated with bad tastes and odors.
6. Model No. MP1200EL includes a capacity monitor that automatically flashes a red light when it is time to replace your filter.
7. Multipure Drinking Water System Housings are warranted for Lifetime (provided that the filter be replaced at least once a year). All exterior hoses and attachments to the System are warranted for one year. Please see the Owner's Manual for complete product guarantee and warranty information.
8. Please see the Owner's Manual for installation instructions and operating procedures.
9. In compliance with New York law, it is recommended that before purchasing a water treatment system, NY residents have their water supply tested to determine their actual water treatment needs. Please compare the capabilities of the Multipure unit with your actual water treatment needs.
10. While testing was performed under standard laboratory conditions, actual performance may vary.
11. The list of substances which the treatment device reduces does not necessarily mean that these substances are present in your tap water.



MP750SB or MP1200EL



MP750SC



MPAD

Operational Specifications	MP750xx	MP1200EL	MPAD
Approximate Service Capacity	750 gallons	1200 gallons	750 gallons
Replacement Filter Type	CB6	CB6	CBAD
Approximate Flow Rate @ 60 psi	0.75 gpm	0.75 gpm	0.75 gpm
Maximum Water Pressure	100 psi/7.0 kg/cm <sup>2</sup>	100 psi/7.0 kg/cm <sup>2</sup>	100 psi/7.0 kg/cm <sup>2</sup>
Minimum Water Pressure	30 psi/2.1 kg/cm <sup>2</sup>	30 psi/2.1 kg/cm <sup>2</sup>	30 psi/2.1 kg/cm <sup>2</sup>
Maximum Operating Temperature	100°F/38°C for cold water use only	100°F/38°C for cold water use only	100°F/38°C for cold water use only
Minimum Operating Temperature	32°F/0°C for cold water use only	32°F/0°C for cold water use only	32°F/0°C for cold water use only

# California Department of Public Health Certification / Registration

State of California  
Department of Public Health  
Water Treatment Device  
Certificate Number  
97 - 1294  
Date Issued: June 23, 2012

**Trademark/Model Designation**

MP7508B  
MP7508C  
MP7508I  
MPCT

**Replacement Elements:** CB6

**Manufacturer:** Multipure International

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

**Microbiological Contaminants**

Cysts (protozoan)  
Turbidity

**Inorganic/Radiological Contaminants**

Asbestos  
Lead  
Mercury  
Radon

**Organic Contaminants**

Chlordane  
PCBs  
Toxaphene  
MTBE  
VOCs

**VOCs by Surrogate:**

Alcohol	Enzin	Simazine
Atrazine	Ethylbenzene	Styrene
Benzene	EDB	1,1,2,2-Tetrachloroethane
Chloroform	Halooxycarbitrils (HAN)	Tetrahydroethylene
Carbon Tetrachloride	Bromochloroacetonitrile	Toluene
Chlorobenzene	Dibromoacetonitrile	2,4,5-TP (Silvex)
Chloroethene	Dichloroacetonitrile	Trichloroacetic Acid
2,4-D	Trichloroacetonitrile	1,2,4-Trichlorobenzene
DBCP	Haloketones (HK)	1,1,1-Trichloroethane
o-Dichlorobenzene	1,1-Dichloro-2-Propanone	1,1,2-Trichloroethane
p-Dichlorobenzene	1,1,1-Trichloro-2-Propanone	Trichloroethylene
1,2-Dichloroethane	Heptachlor	Trichloroethanes (TTHM's)
1,1-Dichloroethylene	Heptachlor Epoxide	Bromodichloromethane
cis-1,2-Dichloroethylene	Heptachlor Epoxide	Bromoforn
trans-1,2-Dichloroethylene	Heptachlor Epoxide	Chloroform
1,2-Dichloropropane	Heptachlor Epoxide	Chlorodibromomethane
cis-1,3-Dichloropropylene	Lindane	Chlorobromomethane
Diisobut	Methoxychlor	Xylenes
	Pentachlorophenol	

**Rated Service Capacity:** 750 gallons

**Rated Service Flow:** 0.75 gpm

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.  
Do not use on water sources with a radon activity greater than 4000 pCi/L and follow the manufacturer's recommended replacement schedule for the carbon filter (to a maximum of one year). System treats radon from drinking water only and does not reduce radon from indoor air.

State of California  
Department of Public Health  
Water Treatment Device  
Certificate Number  
97 - 1295  
Date Issued: June 23, 2012

**Trademark/Model Designation**

Multi-Pure MP1200EL

**Replacement Elements:** CB6

**Manufacturer:** Multipure International

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

**Microbiological Contaminants**

Cysts (protozoan)  
Turbidity

**Inorganic/Radiological Contaminants**

Asbestos  
Lead  
Mercury  
Radon

**Organic Contaminants**

Chlordane  
PCBs  
Toxaphene  
MTBE  
VOCs

**VOCs by Surrogate:**

Alcohol	Enzin	Simazine
Atrazine	Ethylbenzene	Styrene
Benzene	EDB	1,1,2,2-Tetrachloroethane
Chloroform	Halooxycarbitrils (HAN)	Tetrahydroethylene
Carbon Tetrachloride	Bromochloroacetonitrile	Toluene
Chlorobenzene	Dibromoacetonitrile	2,4,5-TP (Silvex)
Chloroethene	Dichloroacetonitrile	Trichloroacetic Acid
2,4-D	Trichloroacetonitrile	1,2,4-Trichlorobenzene
DBCP	Haloketones (HK)	1,1,1-Trichloroethane
o-Dichlorobenzene	1,1-Dichloro-2-Propanone	1,1,2-Trichloroethane
p-Dichlorobenzene	1,1,1-Trichloro-2-Propanone	Trichloroethylene
1,2-Dichloroethane	Heptachlor	Trichloroethanes (TTHM's)
1,1-Dichloroethylene	Heptachlor Epoxide	Bromodichloromethane
cis-1,2-Dichloroethylene	Heptachlor Epoxide	Bromoforn
trans-1,2-Dichloroethylene	Heptachlor Epoxide	Chloroform
1,2-Dichloropropane	Heptachlor Epoxide	Chlorodibromomethane
cis-1,3-Dichloropropylene	Lindane	Chlorobromomethane
Diisobut	Methoxychlor	Xylenes
	Pentachlorophenol	

**Rated Service Capacity:** 1200 gallons

**Rated Service Flow:** 0.75 gpm

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on water containing cysts.  
Do not use on water sources with a radon activity greater than 4000 pCi/L and follow the manufacturer's recommended replacement schedule for the carbon filter (to a maximum of one year). System treats radon from drinking water only and does not reduce radon from indoor air.

State of California  
Department of Health Services  
Water Treatment Device  
Certificate Number  
05 - 1736  
Date Issued: October 20, 2005

**Trademark/Model Designation**

Multi-Pure MPAD  
Multi-Pure MPADC

**Replacement Element(s)**

CB6AD  
CB6AD

**Manufacturer:** Multi-Pure Drinking Water Systems

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

**Microbiological Contaminants and Turbidity**

Cysts  
Turbidity

**Inorganic/Radiological Contaminants**

Asbestos  
Lead  
Mercury

**Organic Contaminants**

Chlordane  
MTBE  
PCB  
Toxaphene  
VOCs

Alcohol	Enzin	Simazine
Atrazine	Ethylbenzene	Styrene
Benzene	EDB	1,1,2,2-Tetrachloroethane
Chloroform	Halooxycarbitrils (HAN)	Tetrahydroethylene
Carbon Tetrachloride	Bromochloroacetonitrile	Toluene
Chlorobenzene	Dibromoacetonitrile	2,4,5-TP (Silvex)
Chloroethene	Dichloroacetonitrile	Trichloroacetic Acid
2,4-D	Trichloroacetonitrile	1,2,4-Trichlorobenzene
DBCP	Haloketones (HK)	1,1,1-Trichloroethane
o-Dichlorobenzene	1,1-Dichloro-2-Propanone	1,1,2-Trichloroethane
p-Dichlorobenzene	1,1,1-Trichloro-2-Propanone	Trichloroethylene
1,2-Dichloroethane	Heptachlor	Trichloroethanes (TTHM's)
1,1-Dichloroethylene	Heptachlor Epoxide	Bromodichloromethane
cis-1,2-Dichloroethylene	Heptachlor Epoxide	Bromoforn
trans-1,2-Dichloroethylene	Heptachlor Epoxide	Chloroform
1,2-Dichloropropane	Heptachlor Epoxide	Chlorodibromomethane
cis-1,3-Dichloropropylene	Lindane	Chlorobromomethane
Diisobut	Methoxychlor	Xylenes
	Pentachlorophenol	

**Rated Service Capacity:** 150 gal.

**Rated Service Flow:** 0.75 gpm

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems claiming cyst reduction may be used on disinfected water that may contain filterable cysts.

For further information, your Independent Distributor:



Multipure International  
Las Vegas Technology Center  
P.O. Box 34630  
Las Vegas, NV 89134-4630  
800.622.9206  
BR170 1306  
email: [headquarters@multipure.com](mailto:headquarters@multipure.com)  
[www.multipure.com](http://www.multipure.com)